RE8040 -F Dⁿ

CSM°

AGUA CONTROL

AGUA CONTROL LLC 5609 E ADAMO DRIVE STE.D TAMPA FL, 33619 (813) 621-7774 (813) 621-7776

Enhanced fouling resistant RO element with thick feed spacer for wastewater reuse

SPECIFICATIONS

General Features Permeate flow rate: 10,000 GPD (39.7 m³/day)

Nominal salt rejection: 99.7%

Effective membrane area: 380 ft² (35.3 m²)

Feed spacer thickness : 34 mil

1. The stated product performance is based on data taken after 30 minutes of operationat the following test conditions:

• 2,000 mg/L NaCl solution at 225 psig (1.5 MPa) applied pressure


- 15% recovery
- 77 °F (25 °C)
- pH 6.5 -7.0
- 2. Minimum salt rejection is 994%.
- 3. Permeate flow rate for each element may vary but will be no more than 15%
- 4. All elements are vacuum sealed in a polyethylene bag containing 1.0% SBS (sodium bisulfite) solution and individually packaged in a card**b** ard box.

Membrane type: Thin-Film Composite
Membrane material: Polyamide(PA)

Element configuration: Spiral-Wound, FRP W rapping

Dimensions and Weight

Model Name	A	В	С	Weight	Part Number	
					Inter - connector	Brine Seal
RE 8040-FDn	40.0 inch (1,016 mm)	8.0 inch (201 mm)	1.12 inch (28 mm)	15 kg	40000308	40000309



- 1. Each membrane elementuppliedwith one brine seal, one interconnector (coupler) and four o-rings.
- All RE8040 elements fit nominal 8.0 inch (201 mm) I.D. pressure vessels.

The information provided in this document is solely for informative purposes it is the user's responsibility to ensure the appropriate usage of this product Woongjin Chemical assumes no obligation, liability or damages incurred for the misuse of the product or for the information provided in this document this document does not express or implies any warranty as to the merchantability or fitness of the product.

RE8040 -FDⁿ







APPLICATION DATA :		
Operating Limits	 Max. Pressure Drop / Element Max. Pressure Drop / 240" Vessel Max. O peratingPressure Max. Feed Flow Rate Min. C oncentrate Flow Rate Max. O peratingTemperature Operating pH Range CIP pH Range Max. Turbidity Max. SDI (15 min) Max. C hlorine C oncentration 	15 psi (0.1 MPa) 60 psi (0.41 Mpa) 600 psi (4.14 MPa) 75 gpm (17.0 m³/hr) 16 gpm (3.6 m³/hr) 113 °F (45 °C) 2.0–11.0 1.0–13.0 1.0 NTU 5.0 < 0.1 mg/L
Design Guidelines for Various Water Sources	 Wastewater Conventional (SDI < 5) Wastewater Pretreated by UF/MF (SDI < 3) Seawater, O pen Intake (SDI < 5) Seawater, Beach Well (SDI < 3) SurfaceW ater (SDI < 5) SurfaceW ater (SDI < 3) Well water (SDI < 3) RO permeate (SDI < 1) 	8–12 gfd 10–14 gfd 7–10 gfd 8–12 gfd 12–16 gfd 13–17 gfd 13–17 gfd 21–30 gfd
Saturation Limits (Using Antiscalants) †	 Langlier Saturation Index(LSI) Stiff and Davis Saturation Index(SDSI) CaSO 4 SrSO 4 BaSO 4 SiO 2 [†]The above saturation limits are typically accepted manufacturers. It is the user's responsibility to ensure concentration are dosed ahead of themembrane system. or damaged due to scale formation are not covered. 	re proper chemical(s) and estem to prevent scale Membrane elements fouled

GENERAL HANDLING PROCEDURES

- Elements contained in the boxes must be kept dry at room temperature (7–32°C; 40–95°F) and should not be stored in direct sunlight. If the polyethylene bag is damaged a new preservative solution (sodium bisulfite) must be added and airtight sealed to prevent drying and biological growth.
- Permeate from the first hour of operation should be discarded to flush out the preservative solution.
- Elements should be immersed in a preservative solution during storage, shipping and system shutdowns to prevent biological growth and freezing. The standard storge solution contains 1% by weight sodium bisulfite or sodium metabisulfite (food grade). For short term storage (i.e. one week or less) 1% by weight sodium metabisulfite solution is adequate for preventing biological growth.
- Keep elements moist at all times after initial wetting.
- Avoid excessive pressure and flow spikes.
- Only use chemicals compatible with the membrane elements and components. Use of such chemicals may void the element limited warranty.
- Permeate pressure must always be equal or less thanthe feed/concentrate pressure. Damage caused by permeate back pressure voids the element limited warranty.

